

Installing Enphase 600 A Consumption CTs

Use this instruction with the *Enphase IQ Gateway Commercial Pro quick install guide* to install consumption monitoring current transformers (CTs). The Enphase IQ Gateway Commercial Pro uses a set of three 600 A split-core CTs for monitoring consumption. They perform metering with an accuracy of $\pm 2.5\%$. Rated at pollution degree 3, you can use the CTs inside electrical equipment in residential environments or harsh industrial conditions. Read and follow all warnings and document in this instruction and the quick Install guide included with your IQ Gateway Commercial Pro. The guide is also available at <https://enphase.com/installers/resources/documentation/accessories>.

SAFETY

SAFETY AND ADVISORY SYMBOLS

	DANGER: This indicates a hazardous situation, which, if not avoided, will result in death or serious injury.
	NOTE: This indicates information particularly important for optimal system operation. Follow instructions carefully.

SAFETY INSTRUCTIONS

	DANGER: To reduce the risk of electric shock, always open or disconnect the circuit from the power-distribution system (or service) of the building before installing or servicing the current transformers.
	DANGER: Risk of electrocution! Do not install CTs when current is flowing in the sensed circuit. Always install CT wires in the terminal blocks before energizing the sensed circuit.
	DANGER: If equipment is used in a manner not specified by Enphase Energy, the protection provided by the equipment may be impaired.
	DANGER: Risk of electric shock. Installation of this equipment includes the risk of electric shock. If the subpanel cannot be de-energized, a qualified electrician can safely install the CTs as directed by connecting the leads first and then placing the CTs around each wire and latch.
	DANGER: Risk of electric shock. Risk of fire. Only qualified personnel should troubleshoot, install, or replace the CTs.
	NOTE: Due to variations in switchboard design and main power feed, there may not always be sufficient space to install CTs.
	NOTE: Do not install the CTs in a switchboard where they exceed 75% of the wiring space of any cross-sectional area within the equipment.
	NOTE: Perform all electrical installations in accordance with all national and local electrical codes.
	NOTE: Restrict installation of current transformers in an area where they would block ventilation openings, or in the area of breaker arc venting.
	NOTE: Not suitable for Class 2 wiring methods and not intended for connection to Class 2 equipment.
	NOTE: Secure current transformer and route conductors so that they do not directly contact live terminals or bus.
	NOTE: When wiring the IQ Gateway Commercial Pro for production and consumption metering, be sure to install the current transformers (CTs) exactly as described for your application.
	NOTE: When installing CTs, it is important to match CT and sense voltage phases. Be sure to consistently identify the two AC lines at three points: the main load center feed, the IQ Gateway Commercial Pro, and the solar production circuit breaker. Wire colors (typically black and red) may not always consistently identify L1 and L2. If in doubt, use a multimeter to check.
	NOTE: Only run active conductors through the CT. The CT can monitor multiple active conductors. You may run more than one wire through the CT if all wires are in the same phase and they fit the opening in the CT.
	NOTE: For indoor use only.

SPECIFICATIONS

SPECIFICATION	CT-600-277-SPLIT
Current transformer type	Split core
Current transformer accuracy (error rate)	<2.5%
Maximum primary current	600 A
Turns ratio	4800
Pollution degree	3
Dimensions (inches)	3.68 × 4.4 × 0.98
Aperture (inches)	1.97 × 1.97
Supported cable size (maximum)	Up to 300 KCMIL conductors
Primary voltage (range)	up to 277 VAC
Frequency	50–60 Hz
Operating temperature	-40°C to 85°C
Humidity	95%
Compliance	UL 2808 certified with service entrance rating, RoHS (latest version)


INSTALLATION

Preparation

- A) If not already done, de-energize the home load panel and the PV system.

Remove any pre-installed Consumption CTs


- A) Remove line 1, line 2, and line 3 conductors circuit to which the Consumption CTs are connected.
- B) Remove the existing CTs.



Install the Consumption CTs


- A) Refer to the diagram on the reverse of this document for wiring.
- B) Install the Consumption CTs on active phases as required:
 - Locate the arrow on the CT label.
 - Make sure that the AC mains wire(s) are de-energized until you have secured the CT wires in the terminal blocks.
 - To monitor consumption on line 1:**
 - Connect the white wire to the white "C1" and the blue wire to the blue "C1" terminal of the meter connector.
 - Clamp the CT on the main supply Line 1. When the Consumption CT is on the Line 1 conductor, the arrow must point toward the load (away from the grid).
 - **To monitor consumption on line 2:**
 - Connect the white wire to the white "C2" terminal and the blue wire to the blue "C2" terminal of the meter connector.
 - Clamp the CT on the main supply Line 2. When the Consumption CT is on the Line 2 conductor, the arrow must point toward the load (away from the grid).
 - **To monitor consumption on line 3:**
 - Connect the white wire to the white "C3" terminal and the blue wire to the blue "C3" terminal of the meter connector.
 - Clamp the CT on the main supply Line 3. When the Consumption CT is on the Line 3 conductor, the arrow must point toward the load (away from the grid).
 - **Insert the meter connector in the meter 2 port.**
- C) Turn on the PV system.

To the solar subpanel





Production CT.

Solid core.
The arrow must point toward the load — away from the solar array.



Consumption CT.

Split core.
The arrows must point toward the load — away from the grid.



Panel board

To grid

Meter 1
PV/Production

Meter 2
PCC/Storage/Consumption



INSTALLATION TIPS

Installing multiple conductors in a single CT

If you need to install multiple conductors in a single CT, you must ensure that the conductors terminate on the same line conductor, so the voltage at the terminals of the two conductors will be zero volts between them.

There are some challenges to this approach:

- It is easy to make a wiring error.
- The conductors must fit within the CT.
- All of the conductors on line 1 must be bundled and with the loads on the line 1 CT.
- All of the conductors on line 2 must be bundled and with the loads on the line 2 CT.
- All of the conductors on line 3 must be bundled and with the loads on the line 3 CT.
- You may need to extend some of the circuits.

It is often possible to run all of the conductors in a service panel through a single set of Consumption CTs.

Installing parallel-connected CTs for 1200 A services and in crowded service panels

It may be difficult to install multiple conductors through a single CT when some of the conductors enter from the bottom of the service panel and others enter from the top. Also, some service panels have 1200 A services that are provided by a set of two 600 A conductors and parallel-connected 600 A circuit breakers. In those scenarios, you can use a set of parallel-connected Consumption CTs to monitor the home's consumption. Do this by installing two Consumption CTs on each line conductor and then parallel-connecting the output conductors at the IQ Gateway Commercial Pro CT wiring terminals or in a wire connector prior to landing in the IQ Gateway Commercial Pro terminals.

Revision history

REVISION	DATE	DESCRIPTION
140-00458-01	November 2025	Initial release.