



## **IQ7HS Microinverter**

The high-powered, smart grid-ready IQ7HS Microinverter with integrated MC4 connectors dramatically simplifies installation while achieving the highest system efficiency.



Part of the Enphase Energy System, the IQ7HS Microinverters integrate with the IQ Gateway, IQ Battery, and the Enphase Installer App monitoring and analysis software.



Connect PV modules quickly and easily to the IQ7HS Microinverters that have integrated MC4 connectors.



IQ7HS Microinverters extend the reliability standards set forth by previous generations and undergo over a million hours of poweron testing, enabling Enphase to provide an industry-leading warranty of up to 25 years.



IQ7HS Microinverters are UL Listed as PV rapid shutdown equipment and conform with various regulations when installed according to the manufacturer's instructions.

#### Easy to install

- · Lightweight and simple
- Faster installation with improved, lighter two-wire cabling
- Built-in rapid shutdown compliant (NEC 2014, 2017, 2020, and 2023)

#### Productive and reliable

- Optimized for high powered 60-cell/120-half-cut-cell, 66-cell/ 132-half-cut-cell, and 72-cell/ 144-half-cut-cell PV modules
- · More than a million hours of testing
- · Class II double-insulated enclosure
- · UL Listed

#### Smart grid-ready

- Complies with advanced grid support, voltage, and frequency ride-through requirements
- Remotely updates to respond to changing grid requirements
- · Configurable for varying grid profiles
- Meets CA Rule 21 (UL 1741-SA) and IEEE 1547:2018 (UL 1741-SB, 3rd Ed.) for single-phase systems

### **IQ7HS Microinverter**

INPUT DATA (DC)	UNITS	IQ7HS-66-M-US
Commonly used module pairings <sup>1</sup>	W	320-460
Module compatibility	_	60-cell/120-half-cut-cell, 66-cell/132-half-cut-cell, and 72-cell/144-half-cut-cell PV modules
Maximum input DC voltage	V	59
Peak power tracking voltage	V	38-43
Operating range	V	20-59
Minimum/Maximum start voltage	V	30/59
Maximum input DC short-circuit current	Α	25
${\rm Maximum\ module\ I_{\rm sc}}$	Α	20
Overvoltage class DC port	_	II
DC port back-feed current	Α	0
PV array configuration	-	1×1 ungrounded array; no additional DC side protection required; AC side protection requires max. 20 A per branch circuit
OUTPUT DATA (AC)		
Peak output power	VA	384 @ 240 VAC, 369 @ 208 VAC
Maximum continuous output power	VA	384 @ 240 VAC, 369 @ 208 VAC
Nominal (L-L) voltage/Range <sup>2</sup>	V	240/211-264, 208/183-229
Maximum continuous output current	_	1.60 A (240 V), 1.77 A (208 V)
Nominal frequency	Hz	60
Extended frequency range	Hz	47–68
AC short-circuit fault current over three cycles	Arms	4.82
Maximum units per 20 A (L-L) branch circuit <sup>3</sup>	_	10 (240 VAC), 9 (208 VAC)
Overvoltage class AC port	_	III
AC port back-feed current	mA	18
Power factor setting	_	1.0
Power factor (adjustable)	_	0.85 leading 0.85 lagging
EFFICIENCY		
CEC weighted efficiency	%	97.0 @ 240 V, 96.5 @ 208 V
MECHANICAL DATA		
Ambient temperature range	°C (°F)	-40 to 60 (-40 to 140)
Relative humidity range	%	4 to 100 (condensing)
DC connector type	_	Stäubli MC4
Dimensions (H × W × D)	mm (in)	212 (8.3) × 175 (6.9) × 30.2 (1.2) without bracket
Weight	kg (lb)	1.1 (2.4)
Cooling	_	Natural convection—no fans
Approved for wet locations	_	Yes
Pollution degree	_	PD3

 $<sup>^{1}</sup> Pairing PV \ modules \ with \ wattage \ above \ the \ limit \ may \ result \ in \ additional \ clipping \ losses. \ See \ the \ compatibility \ calculator \ at \ \underline{enphase.com/installers/microinverters/calculator}.$ 

 $<sup>^{\</sup>rm 2}$  Nominal voltage range can be extended beyond nominal if required by the utility.

 $<sup>^3</sup>$  Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.

MECHANICAL DATA					
Enclosure	_	Class II double-insulated, corrosion-resistant polymeric enclosure			
Environmental category/UV exposure rating	_	NEMA type 6/Outdoor			
FEATURES					
Communication	Power line communication (PLC)				
Monitoring	Enphase Installer App and monitoring options Compatible with IQ Gateway				
Disconnecting means	The AC and DC connectors have been evaluated and approved by UL for use as the load-break disconnect means required by NEC 690 and C22.1-2018 Rule 64-220.				
Compliance	CA Rule 21 (UL 1741-SA), IEEE 1547:2018 (UL 1741-SB 3 <sup>rd</sup> Ed.) for single-phase systems HEI Rule 14H SRD 2.0 UL 62109-1, FCC Part 15 Class B, ICES-0003 Class B CAN/CSA-C22.2 NO. 107.1-01 This product is UL Listed as PV rapid shutdown equipment and conforms with NEC 2014, NEC 2017, and NEC 2020 section 690.12 and C22.1-2018 Rule 64-218 rapid shutdown of PV systems for AC and DC conductors, when installed according to manufacturer's instructions.				

# Revision history

REVISION	DATE	DESCRIPTION
DSH-00562-1.0	August 2024	Initial release.